

Clarification/Corrigendum Dated: 05.12.2024

TO  
**BIDDING DOCUMENT**

<b>Miscellaneous Civil infrastructure works at 600 MW Jhansi Solar Park (Tender no. TUSCO/SOLAR/JSPP/CIVILINFRA/06; Tender Id. 2024_THDC_835266_1)</b>	
<b>BoQ Item No. 8.11 : Construction of New Internal Main Road 1.6 KM FOR SOLAR POWER PARK</b>	<b><u>Clarification</u></b>
Providing and laying bituminous macadam using crushed stone aggregates of specified grading premixed with bituminous binder, transported to site by tippers, laid over a previously prepared surface with paver finisher equipped with electronic sensor to the required grade, level and alignment and rolling with smooth wheeled, vibratory and tandem rollers as per specifications to achieve the desired compaction and density, complete as per specifications and directions of Engineer-in-Charge	Providing and laying bituminous macadam using crushed stone aggregates of specified grading premixed with bituminous binder, transported to site by tippers, laid over a previously prepared surface with paver finisher equipped with electronic sensor to the required grade, level and alignment and rolling with smooth wheeled, vibratory and tandem rollers as per specifications to achieve the desired compaction and density, complete as per specifications and directions of Engineer-in-Charge  50 to 100 mm average compacted thickness with bitumen of grade VG-30 @ 3.50% (percentage by weight of total mix) prepared in Batch Type Hot Mix Plant of 100-120 TPH capacity.
<b>BoQ Item No. 8.12 : Construction of New Internal Main Road 1.6 KM FOR SOLAR POWER PARK</b>	<b><u>Clarification</u></b>
Providing and laying semi- dense Bituminous concrete using crushed stone aggregates of specified grading, premixed with bituminous binder and filler, transporting the hot mix to work site by tippers, laying with paver finisher equipped with electronic sensor to the required grade, level and alignment and rolling with smooth wheeled, vibratory and tandem rollers to achieve the desired compaction and density as per specification, complete and as per directions of Engineer-in-Charge	Providing and laying semi-dense Bituminous concrete using crushed stone aggregates of specified grading, premixed with bituminous binder and filler, transporting the hot mix to work site by tippers, laying with paver finisher equipped with electronic sensor to the required grade, level and alignment and rolling with smooth wheeled, vibratory and tandem rollers to achieve the desired compaction and density as per specification, complete and as per directions of Engineer-in-Charge.  25 mm compacted thickness with bitumen of grade VG-30@ 5% (percentage by weight of total mix) and lime filler @ 2% (percentage by weight of Aggregate) prepared in Batch Type Hot Mix Plant of 100-120 TPH capacity

All other terms & conditions of the tender shall remain unchanged.

The complete Tender Document is available on Central Public Procurement (CPP) Portal Website.

Website: <https://eprocure.gov.in/eprocure/app>

**AGM (C&MM)**  
**TUSCO Limited, 4<sup>th</sup> Floor UPNEDA Bhawan**  
**Vibhuti Khand Gomti Nagar,Lucknow,**  
**Uttar Pradesh (India),**  
**E-mail: [tuscosolar@thdc.co.in](mailto:tuscosolar@thdc.co.in)**