

**CORRIGENDUM NO. 06 DATED: 15.05.2025**  
**TO**  
**BIDDING DOCUMENT**

**TENDER NO.: TUSCO/CSPP/IPEI/2024-25/11**

**Subject: “220kV AIS Substation Package for construction of two Pooling substations (PSS1 & PSS2) of 33/220 kV capacity and 220 kV transmission lines up to 220kV side (incomer) of 220/400 kV Grid Sub-station (GSS) to evacuate power from 500MW & 300MW capacity block Solar Park Project at Mau, Chitrakoot (U.P.)”**

This is to inform all the concerned that the following clarifications/amendments have been made in the subject bid:

- CT Ratio of all 33 kV feeders (to be connected to Inverter Transformers) including spare feeders are to be read as **800-400/1** for all cores. This would apply to the 33 kV Switchgear System of both PSS-1 and PSS-2.
- Current rating for 33 kV Incomer Breakers of 33/220 kV, 125 MVA Transformers, Bus-Couplers, and Busbar at PSS-1 shall be **3150 A** instead of 2500A. Accordingly, CT Ratio for these shall be **3000/1** instead of 2500/1. This shall apply for PSS-1 only.

The timeline for bid submission shall remain unchanged. Bidders are requested to submit their bids as per stipulated schedule.

All other terms & conditions of the tender shall remain unchanged.

The complete Tender Document is available on Central Public Procurement (CPP) Portal Website: <https://eprocure.gov.in/eprocure/app>.

Subsequent Clarification /Amendment/ Corrigendum, if any, shall be uploaded on the above website only.

**AGM (C&MM)**  
**TUSCO Limited, 4<sup>th</sup> Floor UPNEDA Bhawan Vibhuti**  
**Khand Gomti Nagar, Lucknow,**  
**Uttar Pradesh (India),**  
**E-mail: [tuscosolar@thdc.co.in](mailto:tuscosolar@thdc.co.in)**

---O---